



221302110727



中国认可  
国际互认  
检测  
TESTING  
CNAS L20939

# 检验报告

## Test Report

NO:2025-JAJC-BG0981

委托单位：安徽森昌消防科技有限公司

产品名称：水流指示器

型号规格：ZSJZ 200-M-1.6、ZSJZ 50-M-1.6、

ZSJZ 65-M-1.6、ZSJZ 80-M-1.6、

ZSJZ 100-M-1.6、ZSJZ 125-M-1.6、

ZSJZ 150-M-1.6

检验类别：型式试验



玖安检测认证有限公司

Jiu'an Testing and Certification Co.,Ltd

# 注意事項

## REMARKS

1、报告无本公司“检验检测专用章”无效，报告涂改无效。

The report is invalid without the company's "Special seal for inspection and testing", and the report is invalid for alteration.

2、复制报告未重新加盖本公司“检验检测专用章”无效。

Copy the report is not re-stamped the company's "Special seal for inspection and testing" is invalid.

3、报告无编制、审核、批准人签字无效。

The report is invalid without the signature of the preparer, reviewer, or approver.

4、本报告未经本公司批准的复制（全文复制除外）或以其他任何形式的篡改均属无效。

Any copy of this report (except full-text copy) or any other form of tampering without the approval of the company shall be null and void.

5、对检验报告若有异议，请于收到报告之日起十五日内向本检验公司提出。

If you have any objection to the inspection report, please submit it to our inspection company within 15 days after receiving the report.

6、检验报告仅对受检样品负责，测试结果仅反映对该样品的评价。

The test report is only responsible for the sample under test, and the test results reflect only the evaluation of the sample.

7、委托单位对样品的代表性和资料的真实性负责，否则本检测公司不承担任何相关责任。

The entrusted entity shall be responsible for the representativeness of the samples and the authenticity of the data, otherwise the testing company shall not bear any relevant responsibility.

---

地址：福建省泉州市南安市溪美街道安山路1号      电话：0595-86068119

网址：[www.jajczx.com](http://www.jajczx.com)    邮箱：[jiuantesting@163.com](mailto:jiuantesting@163.com)    邮编：362300





## 检验报告

NO:2025-JAJC-BG0981

第1页 共8页

产品名称	水流指示器	商标	森昌
型号规格	ZSJZ 200-M-1.6、ZSJZ 50-M-1.6、ZSJZ 65-M-1.6、ZSJZ 80-M-1.6、ZSJZ 100-M-1.6、ZSJZ 125-M-1.6、ZSJZ 150-M-1.6		
生产者	安徽森昌消防科技有限公司		
生产企业	安徽森昌消防科技有限公司		
检验类别	型式试验		
生产日期	2025年05月	到样日期	2025年05月20日
样品数量	主型4只，分型各2只	样品状态	完好
送样地点	玖安检测认证有限公司	检验时间	2025年07月09日
检验依据	GB 5135.7-2018《自动喷水灭火系统 第7部分：水流指示器》		
检验项目	外观标志；规格；额定工作压力；叶片；信号输出部件；灵敏度；工作循环；抗外力冲击性能；过载性能；耐水压性能；机械强度；耐电压能力及绝缘电阻		
检验结论	经检验，所检项目符合 GB 5135.7-2018 标准要求，判定合格  (检验检测专用章) 签发日期: 2025年08月02日		
备注	ZSJZ 200-M-1.6 为主型。		

批准: 卫东瑞金

审核: 戴少阳

编制: 唐其升